

Our Ref: GH/M100110

22<sup>nd</sup> April 2010

Polytech Industries LLC  
Post Box No. 35892  
Industrial Zone III  
25, 26, 27 & 28  
Al Hamara  
Ras Al Khaimah  
UAE

Dear Sir

**WATER REGULATIONS ADVISORY SCHEME**

**"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"**

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

**ETHYLENE PROPYLENE DIENE MONOMER (EPDM) - MATERIAL ONLY**

**5365**

EW50 (shore hardness 50A), EW65 (shore hardness 65A) & EW80 (shore hardness 80A). Black coloured EPDM rubber sheet material. Tested in-radius size 0.5mm. For use with hot and cold water up to 70°C.

Test Report: MAT/LAB 750M, 237A, 238A & 239A

**0807528**

**POLYTECH INDUSTRIES LLC**

An entry, as above, will accordingly be included in the Water Fittings Directory on-line, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings Directory on-line: this may be abbreviated to "Water Regulations Advisory Scheme - Approved Material" or "WRAS - Approved Material". **Approval of this product does not signify the approval of its mechanical or physical properties for any use.**

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in July 2013.

Yours faithfully



Gareth Harris  
WRAS Approvals Administrator  
Water Regulations Advisory Scheme